Product fiche

Delegated Regulation (EU) 2015/1187

Energy efficiency index of solid fuel cogeneration boiler 121

Temperature control

From temperature control fiche

ClassI = 1, ClassII = 2, ClassIII = 1.5, ClassIV = 2, ClassV = 3, ClassVI = 4, ClassVII = 3.5, ClassVIII = 5

\+ 4

Supplementary boiler

From boiler fiche

Seasonal space heating energy efficiency (in %) or energy efficiency index

(- – 121) x - = - -

Solar contribution

From solar device fiche

Collector size (in m²) | Tank volume (in m³) | Collector efficiency (in %) | Tank rating A+ = 0.95, A = 0.91, B = 0.86, C = 0.83, D-G = 0.81

(- x - + - x -) x 0.7 x (- / 100) x - = + -

Energy efficiency index of the package 125

Energy efficiency class of the package

☐ G	☐ F	☐ E	☐ D	☐ C	☐ B	☐ A	☐ A+	☑ A++	☐ A+++
<30	≥30	≥34	≥36	≥75	≥82	≥90	≥98	≥125	≥150

The energy efficiency of the package of products provided for in this fiche may not correspond to its actual energy efficiency once installed in a building, as this efficiency is influenced by further factors such as heat loss in the distribution system and the dimensioning of the products in relation to building size and characteristics.

Model placed on the Union market from 10/05/2021

EPREL registration number: 725413

https://eprel.ec.europa.eu/qr/725413

Supplier: HARGASSNER Ges mbH (Manufacturer)

Website: www.hargassner.com

Customer care service:

Name: Hargassner Ges mbH

Website: www.hargassner.com

Email: office@hargassner.at

Phone: +43 7723 / 5274

Address:
Anton Hargassner Straße 1
4952 Weng im Innkreis
Austria